



Ref. Certif. No.

CN41662-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switch

Name and address of the applicant

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Name and address of the factory

ABB Oy, Protection and Connection
P.O. Box 622 (Muottitie 2A) 65101 Vaasa, Finland

Note: When more than one factory, please report on page 2

Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

OTM□F□□□□□□

Additional information (if necessary may also be reported on page 2)

The original CB No. is CN41662 , dated 2017-11-10 . The first modification is to add parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

GQI-POW-2017012-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn



Signature: Lu Mei

CB 0052432

Type: OTM□F□□□□C□;

U_i : 750V;

U_{imp} : 8kV

I_{th} : 125A;

U_e : AC220/230/240V(2P), AC380/400/415V(3P/4P);

I_e : 32A, 40A, 50A, 63A, 80A, 100A, 125A (For AC-33B, derating capacity to 80A for 100A and 125A);

Utilization category: AC-31B, AC-32B(20D/12D/21D); AC-33B(12D/21D);

I_q : 50kA;

Class of equipment: PC;

Method of control the transfer: ATSE;

Number of poles: 2P, 3P, 4P;

U_{imp} (controller): 6kV;

The ATSE products have manual transfer function.

Page 1 of 1

Additional information (if necessary)

Date: Jun.10,2019

Signature: 

Lu Mei

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN41662-M1

Name of the factory**Address of the factory**1.ABB Xinhui Low Voltage
Switchgear Co., Ltd.Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen, Guangdong Province, P.R.China

Additional information (if necessary)

Date: Jun.10,2019

Signature: 

Lu Mei