



# Certificate of Conformity

**Number:** C211-0002/22 **Project file:** C20220085

**Product:** Circuit breaker

**Type reference:** S200M, S200 and S200L series  
Type ref.: S20.M (10 kA); S20 (6 kA); S20.L (4.5 kA)

**Trademark:** ABB

**Applicant:** ABB - Stotz - Kontakt G.m.b.H  
Eppelheimer strasse 82, 69123 Heidelberg, Germany

**Manufacturer:** ABB - Stotz - Kontakt G.m.b.H  
Eppelheimer strasse 82, 69123 Heidelberg, Germany

**Place of manufacture:** ABB Bulgaria EOOD - Rakovski Branch -  
Industrial Zone Rakovski Municipality, 4150 Rakovski, Bulgaria

This certificate is granted subject to the SIQ's rules on product certification. SIQ certifies the conformity of the products with the requirements of the listed standards.

**Ratings:** S20.M (AC 230/400 V; B 6-63 A; C/D 0,5-63 A; Number of poles: 1; 2; 3; 4; 1+N; 3+N; Icn: 10 kA)  
S20 (6 kA) & S20.L (4,5 kA) (AC 230/400 V; B 1-63 A; C/D 0,5-63 A; Number of poles: 1; 2; 3; 4; 1+N; 3+N)

**Standard:** EN 60898-1:2003 + A1:2004 + A11:2005 + A12:2008 + A13:2012

**Test report:** T211-0057/22 (2022-01-26)

**Remarks:** This certificate shall apply to the products identical to the tested sample and shall remain valid for the period of 3 years until 2025-01-26 or until the validity date of the listed standards, whichever occurs earlier.

**Date:** 2022-01-26

**Authorized signature:** Bojan Pečavar

*Only integral publication of this certificate is allowed. This certificate may only be reproduced in its entirety and without any changes. On request SIQ will give information about the validity of the certificate.*